

PERFORMA FOR INSPECTION REPORT REGARDING PREVENTION OF FIRE & SAFETY MEASURES

(HIGH RISE/MULTISTOREY BUILDINGS, HOSPITALS, NURSING-HOMES, CORPORATE OFFICES, FACTORIES AND HAZARDOUS STORAGES.)

DATE OF INSPECTION :30/05/2024

Sr. No.	DETAILS OF BUILDING/PREMISES	DETAIL OF BUILDING/PREMISES/FIRE SAFETY MEASURES
1	Name of the Building/Premises(Location &address)	St Josephs School Raikot Road Sanghera Barnala Raikot Road, Near Gowshala, Sanghera, Barnala
2	Name and address of the owner with contact no.(s)	Biju joseph s/o Oouseph Kannampuzha Vareed, Raikot Road, Near gaushala, sanghera, Barnala.
3	Name and address of the occupier(s) with contact no.(s)	Biju joseph s/o Oouseph Kannampuzha Vareed, Raikot Road, Near gaushala, sanghera, Barnala.
4	Total area of the Premises.	18836 SQ. M
5	Total covered area.	3097 SQ. M
6	Height of the building from ground level .	12 M
7	Number of basements &its area.	NIL
8	Number of sanctioned floors.	FOUR
9	Number of actual floors.	FOUR
10	Parking area.	OPEN SPACE IN THE BUILDING
11	Details of surrounding properties: a) Left b) Right c) Back d) Front	Left : Gowshala Right : House Front : Road Back : House
12	Number of main gates with size.	ONE
13	Number of fire extinguishers installed in the building on each floor with capapcity, type with ISI marking, number and date of manufacturing.	10 ABC TYPE FIRE EXTINGUISHER 2 CO2 TYPE FIRE EXTINGUISHER
14	Detail of Hose reel on each floor indicating size and length of rubber pipe	HOSE REEL ON EACH FLOOR
15	Details of Wet riser, Down comer, No. of landing valve, delivery hose, branch pipe and hose cabinet on each floor.	ONE LANDING VALVE WITH HOSE BOX
16	No. of yard hydrant with details.	NA
17	Whether basement is being used for parking, storage or office. Has the basement sprinkler system? Give all details.	NA
18	No. of manual fire alarms installed in the building.	NA
19	Details of automatic fire detection system, P A system provided in the building.	NA
20	Details of control panels.	STANDARD
21	Details of Water Storage capacity overhead/underground tank with size	WATER STORAGE 5000 LTR.
22	Details of fire pump with Head and Make. a) Jockey Pump b) Main Pump c) Diesel Pump	FIRE PUMP OF 450 LPM

23	Position of fire service inlet (2 way,3 way,4 way).	NA
24	No. of stair case with size.	ONE STAIR CASE
25	No. of lifts and ramps with details of communication system.	NA
26	Details of means of escape.	DIFFERENT SIDE GATES
27	Stand-by source of power supply with all details of Gen. set and location of switch gear.	NO
28	Is building centrally air conditioned? Give details.	NO
29	Have all exits and direction of travel in each exit been sign posted?	YES
30	Do the fire safety measures conform to the norms of NBC ?	YES
31	Details of Previous NOC (In renewal cases) (1) Name of the issuing authority (2) Date up to which it is valid.	RENEW NOC
Recommendation of Inspection Officer: - 1. Maintain Fire system in working condition. 2. Conduct Periodic Fire Drill & Fire Training for Staff. 3. Do not obstruct Exit Doors and Staircase.		
Signature: Name of inspecting officer:JASPREET SINGH Designation:FSO Contact no.: 9872000141 		